



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 3/15/10

Code 52.1.7-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY- ~~Dashed line through material to be deleted~~, underline material to be added)

Use second sheet for any material requiring more space.

Code Title Indiana Residential Code		Edition 2009
Section number and title R1003.3 Seismic reinforcing		Page 449
Proponent SW Indiana Builders and Building Officials	Title	
Address 2175 N Cullen Ave; Evansville, IN 47715 Center Complex; Room 310; Evansville, IN 47708		Phone 812-479-6026 812-436-7868
<input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution PROPOSED CODE CHANGE (Check One)		
<p>Change Section R1003.3 to read as follows: Masonry or concrete chimneys shall be constructed, anchored, supported and reinforced as required in this chapter. In Seismic Design Category D0, D1 or D2 <u>C1</u> masonry and concrete chimneys shall be reinforced and anchored as detailed in Section R1003.3.1, R1003.3.2 and R1003.4. In Seismic Design Category A, B or C, reinforcement and seismic anchorage is not required.</p>		
REASON		
<p>These amendments are part of the Seismic Package for C1 in the 2005 InRC, and need to be continued.</p>		
REVIEW RECOMMENDATION		
Approve 18-0-0 3/16/10		
Disapprove		
Approve as amended		
Further Study		